



Certificado AENOR de Producto



075/000035

AENOR certifica que la organización

PRYSMIAN CABLES SPAIN, S.A.

con domicilio social en CARRETERA C-15 KM 2. PI. MASIA D'EN NOTARI
08800 VILANOVA i LA GELTRÚ (Barcelona - España)

suministra **Cable eléctrico de distribución en media tensión con
aislamiento de HEPR y cubierta de poliolefina. Sin
propiedades especiales ante la reacción al fuego.**

conforme con UNE-HD 620-9E:2012/1M:2022

Designación HEPRZ1 Al
Marca Comercial PRYSMIAN [CNE] EPROTENAX H COMPACT
Tensión de Servicio Uo/U (Um) 12/20 (24) kV; 18/30 (36) kV
Limitación Conductor de Aluminio (K Al): 1x50 mm²; 1x95 mm²; 1x150 mm²;
1x240 mm²; 1x400 mm²; 1x630 mm².

Tipo 9E-1
Obtención longitudinal Sin obtención

Centro de producción CARRETERA C-15 KM 2. PI. MASIA D'EN NOTARI
08800 VILANOVA i LA GELTRÚ (Barcelona - España)

Esquema de certificación Para conceder este Certificado, AENOR ha ensayado el producto y ha comprobado el sistema de la calidad aplicado para su elaboración. AENOR realiza estas actividades periódicamente mientras el Certificado no haya sido anulado, según se establece en el Reglamento Particular RP 75.02.

Este certificado anula al 075/000035, de fecha 2022-01-31

Primera emisión 2006-10-31
Modificación 2023-02-09
Expiración 2027-01-27

Rafael GARCÍA MEIRO
CEO





AENOR Product Certificate



075/000035

AENOR certifies that the organization

PRYSMIAN CABLES SPAIN, S.A.

registered office CARRETERA C-15 KM 2. PI. MASIA D'EN NOTARI
08800 VILANOVA i LA GELTRÚ (Barcelona - Spain)

supplies **Medium Voltage Power Distribution electric cable, HEPR insulated and PO sheathed. Without special reaction to fire characteristics.**

in compliance with UNE-HD 620-9E:2012/1M:2022

Designation HEPRZ1 Al
Trade Mark PRYSMIAN [CNE] EPROTENAX H COMPACT
Rated Voltage U_o/U (Um) 12/20 (24) kV; 18/30 (36) kV
Restriction Aluminium Conductor (K Al): 1x50 mm²; 1x95 mm²; 1x150 mm²;
1x240 mm²; 1x400 mm²; 1x630 mm².
Type 9E-1
Longitudinal obturation No obturation

Production site CARRETERA C-15 KM 2. PI. MASIA D'EN NOTARI
08800 VILANOVA i LA GELTRÚ (Barcelona - Spain)

Certification scheme In order to grant this Certificate, AENOR has tested the product and has verified the quality system implemented for its manufacture. AENOR performs these tasks periodically while the Certificate has not been cancelled, in accordance with Specific Rules RP 75.02.

This certificate supersedes 075/000035, dated 2022-01-31

First issued on 2006-10-31
Modified on 2023-02-09
Validity 2027-01-27

Rafael GARCÍA MEIRO
CEO

